

Phone : 033-2545-2113 (Lab), 9831248353 (Lab), 9748173283

FORUM OF SCIENTISTS, ENGINEERS & TECHNOLOGISTS (FOSET)

BARRACKPORE SUB-CENTRE

"ANIMA APARTMENT", Harisava Road, P.O. Nonachandanpukur, Barrackpore,
North 24 Parganas, Kolkata-700 122
Email : fosebtkp@yahoo.in

Date : 17.07.2021

Water Testing Report

Name of School : Central Model School
Address : 23, River Side Road, Barrackpore, Kol-700120
Type of Source : Submersible Pump Water
Date of Receiving : 16.07.2021
Date of Testing : 16.07.2021 – 17.07.2021


• Chemical Test:-

Parameters	Test Results	Permissible limit
pH	7.59	6.5-8.5
Total Hardness(mg/l)	232	600
Iron(mg/l)	0.11	1
Manganese(mg/l)	0.07	0.3
Turbidity(NTU)	1.10	5
Arsenic(mg/l)	0.00	0.01

Bacteriological Test:-

Parameters	Test Results	Permissible limit
Total Coliform(CFU/100 ml)	0	0

NB:- Testing is done on the basis of the sample supplied by the School


Signature of the Chemist/Bacteriologist



FORUM OF SCIENTISTS, ENGINEERS & TECHNOLOGISTS (FOSET)

Head Office : 15N, Lindsay Street, New CMC Building (5th Floor), New Market Complex, Kolkata-700 087
Phone : 2252-9675, Fax : 2252-0521, E-mail : fosebtkp@yahoo.in
Regd. Office : 6/1, Sudder Street, Kolkata-700 016, Regn. No. : S/54424 of 1986-87

FORUM OF SCIENTISTS, ENGINEERS & TECHNOLOGISTS (FOSET)

BARRACKPORE SUB-CENTRE

"ANIMAAPARTMENT", Harisava Road, P.O. Nonachandanpukur, Barrackpore,
North 24 Parganas, Kolkata-700 122

Email : fosebtkp@yahoo.in

Date : 17.07.2021

Water Testing Report

Name of School : Central Model School

Address : 23, River Side Road, Barrackpore, Kol-700120

Type of Source : Cantonment Supply

Date of Receiving : 16..07.2021

Date of Testing : 16.07.2021 – 17.07.2021

• Chemical Test:-

Parameters	Test Results	Permissible limit
pH	7.80	6.5-8.5
Total Hardness(mg/l)	112	600
Iron(mg/l)	0.08	1
Manganese(mg/l)	0.01	0.3
Turbidity(NTU)	1.34	5
Arsenic(mg/l)	0.00	0.01

Bacteriological Test:-

Parameters	Test Results	Permissible limit
Total Coliform(CFU/100 ml)	0	0

NB:- Testing is done on the basis of the sample supplied by the School

Suman Chakrabarti

Signature of the Chemist/Bacteriologist



FORUM OF SCIENTISTS, ENGINEERS & TECHNOLOGISTS (FOSET)

Head Office : 15N, Lindsay Street, New CMC Building (5th Floor), New Market Complex, Kolkata-700 087

Phone : 2252-9675, Fax : 2252-0521, E-mail : fosebtkp@yahoo.in

Regd. Office : 6/1, Sudder Street, Kolkata-700 016, Regn. No. : S/54424 of 1986-87